

TEST REPORT

1. Applicant

Name : Young Tech Co., Ltd.
Address : 3022. Hagun-ri, Yangchon-eup, Gimpo-city
Kyunggi-do, Korea

2. Products

Name : SMART POSITIONER
Model/Type : YT-3400
Manufacturer : Young Tech Co., Ltd.
Remark : -

3. Test Standard/Method : IEC 60529:2001, KS C IEC 60529:2006


4. Test Results : IP66 (Refer to document)

5. Use of Report : For Quality Control

6. Date of Application : 2013. 01. 23

7. Date of Issue : 2013. 01. 28

Tested by



Machinery Convergence Technology Center
Chang-ho Kim

Approved by



Machinery Convergence Technology Center
Leader Jun-gu Kang

The above test report is the accredited test results by Korea Laboratory Accreditation Scheme, which signed the ILAC-MRA.

Korea Testing Laboratory

TEST RESULTS

for Degree of protection provided by enclosures(IP Code)

1. Test Results

Code letters	IP	Test method and Record	Results
<p>1st Characteristic numerals</p> <p>Against ingress of solid foreign objects</p>	6	<p>1. CONDITIONS</p> <p>1.1 Talcum powder(mesh) : Wire diameter=50 μm, width between wires=75 μm</p> <p>1.2 Amount of talcum powder of the test chamber : 2kg/m'</p> <p>2. TEST</p> <p>2.1 Volume of the enclosures: about 1,550 cm'</p> <p>2.2 Reduction air pressure : -2.0 kPa (-200 mmH₂O)</p> <p>2.3 Flow rate : 0.16 LPM</p> <p>2.4 Extraction rate per hour : 6.2 volumes/h</p> <p>2.5 Test duration : 8 hours</p>	Pass
<p>2nd Characteristic numerals</p> <p>Against ingress of water with harmful effects</p>	6	<p>1. CONDITIONS</p> <p>1.1 Internal diameter of the nozzle : 12.5 mm</p> <p>1.2 Delivery rate : 100 LPM±5%</p> <p>1.3 Core of the substantial stream : Circle of 120 mm diameter at 2.5 m distance from the nozzle</p> <p>1.4 Distance from nozzle to enclosure surface : Between 2.8 m</p> <p>2. TEST</p> <p>2.1 The duration of the test is : 3 minutes</p>	Pass

2. Reference Data

- (1) Test conditions : 20.1 °C, 44 %RH, 86~106 kPa
- (2) Size : 126.5 mm×248 mm×153.3 mm
- (3) Rating : SIGNAL 4~20 mA
- (4) This test was conducted only on body part but not pressure gauge.